

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0026:210

Page 1 of 1

CATEGORY: Miscellaneous Devices/Control Unit accessories

LISTEE: Simplex, 100 Simplex Dr., Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *Fax (978) 731-8881

DESIGN: Models 4120-8301, -8321, -8703 and -8723 Network Processing Units (NPU) with color touchscreen access. Power-limited. Units provide local and proprietary receiving unit type service when used in conjunction with listee's listed compatible Model 4100/4120 fire alarm control panel (CSFM 7165-0026:160 & 7170-0026:187). Models 4120-8321, -8723 additionally provide audio evacuation capabilities. These NPU receivers are intended to be with Model 4100/4120 control panels in a "4120" network configuration.

Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Primary: 120 VAC, 6A; 220/240 VAC, 3A
Secondary: 12 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as network processing units for the type of service as described under "Design".

*Rev. 05-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 13, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager